

Clarence Cannon
Salt River, Ralls Co, Missouri
Mississippi Valley Division (CEMVD)
St. Louis District

Unit 1

Turbine Type: Kaplan
Turbine Manufacturer:Allis-Chalmers
Horsepower: 42,900
RPM: 128.6
Rated Head: 75 feet
Generator Manufacturer:General Electric
Generator Rated KVA:28,421
Generator Rated PF: 95%
Generator Rated KW: 27,000
Generator Max. KW: 27,000
Generator Rated KV: 13.8

Unit 2

Turbine Type: Francis
Turbine Manufacturer:Allis-Chalmers
Horsepower: 42,900
RPM: 75
Rated Head: 75 feet
Generator Manufacturer:General Electric
Generator Rated KVA:28,421
Generator Rated PF: 95%
Generator Rated KW: 27,000
Generator Max. KW: 27,000
Generator Rated KV: 13.8