



Cougar

McKenzie River, Lane Co, Oregon

Northwestern Division (CENWD)

Portland District

Units 1 - 2

Turbine Type:	Francis
Turbine Manufacturer:	Voith (Installed in 1988)
Horsepower:	17,250
RPM:	400
Rated Head:	321 feet
Generator Manufacturer:	Elliott
Generator Rated KVA:	13,158
Generator Rated PF:	95%
Generator Rated KW:	12,500
Generator Max. KW:	14,375
Generator Rated KV:	13.8