

Libby
Kootenai River, Lincoln Co, Montana
Northwestern Division (CENWD)
Seattle District

Units 1 - 5

Turbine Type:	Francis
Turbine Manufacturer:	Allis-Chalmers
Horsepower:	165,000
RPM:	128.6
Rated Head:	300 feet
Generator Manufacturer:	Westinghouse (Rewound by General Electric circa 1982)
Generator Rated KVA:	110,526
Generator Rated PF:	95%
Generator Rated KW:	105,000
Generator Max. KW:	120,000
Generator Rated KV:	13.8