



Lookout Point

Willamette River, Lane Co, Oregon

Northwestern Division (CENWD)

Portland District

Units 1 - 3

Turbine Type:	Francis
Turbine Manufacturer:	Pelton
Horsepower:	52,500
RPM:	128.6
Rated Head:	185 feet
Generator Manufacturer:	General Electric
Generator Rated KVA:	42,105
Generator Rated PF:	95%
Generator Rated KW:	40,000
Generator Max. KW:	46,000
Generator Rated KV:	13.8